



Indiana Center for Coal Technology Research

# Sulfur Dioxide Control Technologies In Electric Power Plants

## CCTR Basic Facts File #5

Brian H. Bowen, Marty W. Irwin

The Energy Center at Discovery Park  
Purdue University  
CCTR, Potter Center, 500 Central Drive  
West Lafayette, IN 47907-2022

<http://www.purdue.edu/dp/energy/CCTR/>

Email: [cctr@ecn.purdue.edu](mailto:cctr@ecn.purdue.edu)

April 2007





## Roadmap Performance Target Best technology Capability


|                        | Reference Plant*                                  | 2010                         | 2020                         |
|------------------------|---|------------------------------|------------------------------|
| Air Emissions          | 98% SO <sub>2</sub> removal                       | <u>99%</u>                   | <u>&gt;99%</u>               |
|                        | 0.15 lb/10 <sup>6</sup> Btu NO <sub>x</sub>       | 0.05 lb/10 <sup>6</sup> Btu  | <0.01 lb/10 <sup>6</sup> Btu |
|                        | 0.01 lb/10 <sup>6</sup> Btu<br>Particulate Matter | 0.005 lb/10 <sup>6</sup> Btu | 0.002 lb/10 <sup>6</sup> Btu |
|                        | Mercury (Hg)                                      | 90% removal                  | 95% removal                  |
| By-Product Utilization | 30%   | 50%                          | near 100%                    |

\*Reference plant has performance typical of today's technology;  
Improved performance achievable with cost/efficiency tradeoffs.

Total control & elimination of SO<sub>2</sub> is on the roadmap for prevention of acid rain



## Sulfur in Coals



Although coal is primarily a mixture of carbon (*black*) & hydrogen (*red*) atoms, sulfur atoms (*yellow*) are also trapped in coal, primarily in two forms. In one form, the sulfur is a separate particle often linked with iron (*green, pyritic sulfur*) with no connection to the carbon atoms, as in the center of the drawing (*fools gold*). In the second form, sulfur is chemically bound to the carbon atoms (*organic sulfur*), such as in the upper left



## Amount of Sulfur in Coals




| Supply State  | Sulfur (% weight) | Heat Content (Btu/lb) |
|---------------|-------------------|-----------------------|
| Indiana       | 2.136             | 11,101                |
| Illinois      | 2.445             | 10,860                |
| Kentucky      | 1.034             | 12,289                |
| Ohio          | 3.157             | 11,703                |
| Pennsylvania  | 2.011             | 12,927                |
| Virginia      | 0.728             | 13,905                |
| West Virginia | 1.934             | 12,654                |
| Wyoming       | 0.239             | 8,829                 |

Indiana average sulfur content = 2.1% by weight



# Emission Control Strategies for Power Plants




Clean Air Act of 1970 established national standards to limit such pollutants as Sulfur Dioxide,  $\text{SO}_2$

1977 Amendment resulted in installation of  $\text{SO}_2$  control technologies for coal-fired boilers

1990 Clean Air Act Amendments required further reductions in  $\text{SO}_2$  and  $\text{NO}_x$  power plant emissions that contribute to acid rain







## Coal Use & Reductions in SO<sub>2</sub> Emissions from Power Plants

Coal is being burned more cleanly today than ever before. Air pollution from coal is decreasing, while coal use is increasing. Coal-fired power plants in the U.S. have reduced their SO<sub>2</sub> (Sulfur Dioxide) emission rate (lbs SO<sub>2</sub>/Ton coal burned) by 71% from 1976 to 1999



# Indiana Coal-Fired Generation & Emissions





|           | <b>SO<sub>2</sub><br/>emissions<br/>(Tons)</b> | <b>SO<sub>2</sub><br/>RANK</b> |
|-----------|--|--------------------------------|
| <b>IL</b> | 437,593  |                                |
| <b>IN</b> | <b>878,196</b>                                 | <b>3<sup>rd</sup></b>          |
| <b>KY</b> | 585,141  | <b>5<sup>th</sup></b>          |
| <b>OH</b> | 1,232,450                                      | <b>1<sup>st</sup></b>          |
| <b>PA</b> | 951,373  | <b>2<sup>nd</sup></b>          |
| <b>TX</b> | 577,122  |                                |
| <b>WV</b> | 598,053  | <b>4<sup>th</sup></b>          |



## SO<sub>2</sub> Emissions from Utilities by State in 2000 (Tons)

2004 Indiana SO<sub>2</sub> emissions from utilities = 797,000 Tons





## Methods of Controlling SO<sub>2</sub> From Coal-Fired Power Plants

Methods include:

- Cleaning the coal to remove the sulfur
- Switching to lower SO<sub>2</sub> fuel
- Purchasing SO<sub>2</sub> allowances
- Installing flue gas desulfurization systems, FGD




## Clean Coal & Remove SO<sub>2</sub>

Coal washing removes 25% to 40% of the sulfur.

Only the pyritic sulfur is washed out.

Organic sulfur doesn't wash out





Coal washing involves grinding the coal into smaller pieces & passing it through a process called gravity separation. Technique involves feeding the coal into barrels containing a fluid that has a density which causes the coal to float, while unwanted material sinks & is removed from the fuel mix





## Switch to Lower SO<sub>2</sub> Coal



Transportation Rate per Ton


What is the transportation cost (\$/Ton mile)?

Midwest utilities are importing western coals with their low sulfur content but transportations costs are increasing & extra railroad capacity is needed





# SO<sub>2</sub> Allowance Prices, \$/Ton SO<sub>2</sub>



Source: Air Daily



## Flue Gas Desulfurization Systems, FGD

FGD systems are normally known as wet scrubbers or dry scrubbers (defined according to the state of the by-product)

- Wet Scrubbers – Most common technology



Others (used to much lesser extent):

- Spray dryers
- Dry (sorbent) injection systems
- Regenerable systems
- Circulating fluid-bed & moving bed scrubbers
- Combined SO<sub>2</sub>/NO<sub>x</sub> removable systems



## Flue Gas Desulfurization, FGD since 1970s

FGD systems are used to remove  $\text{SO}_2$ . "Wet scrubbers" are the most widespread method & can be up to 99% effective







## Duct Sorbent Injection

### Duct Spray Drying

Second most used method – over 12,000MW of total capacity. Lime is usually the sorbent used. A slake-lime slurry is sprayed directly into the ductwork to remove SO<sub>2</sub>. Reaction products & fly ash are captured down-stream in the particulate removal Device

### Dry Sorbent Injection (in-duct dry injection)

Hydrated lime is the sorbent typically used. It is injected either upstream or downstream of a flue gas humidification zone

### Regenerative Processes

Regenerate the alkaline reagent. Process is costly.



## Extent of Global SO<sub>2</sub> Controlled Capacity on Power Plants (MW)

| Year | World    | USA       |
|------|----------|-----------|
| 1970 | None     | None      |
| 1980 | 30,000   | 25,000    |
| 1990 | 130,000  | 75,000    |
| 2000 | 230,000* | 100,000** |

\* 87% are wet scrubbers

\*\* 10% of U.S. total 1,105,227MW (78% of MW are thermal)



## Scrubber Capital Costs

### Medium Removal Technology

\$50,000/MW, with 70% SO<sub>2</sub> removal

### High Removal Technology

\$250,000/MW, with 95% SO<sub>2</sub> removal

< \$150,000 /MW, SO<sub>2</sub> emissions could be cut in half  
& mercury emissions could be reduced by >60%





## Scrubbers on Indiana's 10 Largest Power Stations 2005

| Station<br>(Age of units)            | Utility            | MW            | Station<br>Efficiency<br>(%) | IN coal<br>of total<br>coal used<br>(%) | WY coal<br>of total<br>coal used<br>(%) | SO <sub>2</sub><br>(Tons) | MW with<br>Scrubbers<br>in 2005<br>(MW) | MW<br>Scrubbed<br>in 2005<br>(%) | Scrubber<br>Efficiency<br>in 2005<br>(%) | Scrubber Installations<br>Date installed per unit<br><b>EPA Model Results for 2015</b>                |
|--------------------------------------|--------------------|---------------|------------------------------|---|---|---------------------------|---|----------------------------------|--|---|
| 1. <b>Gibson</b><br>1975-1982        | <b>Duke Energy</b> | 3,131         | 32.2                         | 79%                                     | 0%                                      | 136,536                   | <b>1,336</b>                            | <b>43%</b>                       | 89%                                      | Unit 1 – 2007, Unit 2 – 2007<br>Unit 3 – 2006<br>Unit 4 – Upgrade in 2005<br>Unit 5 – Upgrade in 2008 |
| 2. <b>Rockport</b><br>1984-1989      | <b>IMP.Co</b>      | 2,600         | 35.4                         | 16%                                     | <b>84%</b>                              | 53,561                    | <b>0</b>                                | <b>0</b>                         |  | Unit 1<br>Unit 2  |
| 3. <b>R M Schahfer</b><br>1976-1986  | <b>NIPSCO</b>      | 1,780         | 30.6                         | 21%                                     | <b>58%</b>                              | 35,301                    | <b>847</b>                              | <b>48%</b>                       | 90%                                      | Unit 1 - Unit 2 -<br>Unit 3 - Unit 4 -<br>Unit 5 - Unit 6 -   |
| 4. <b>Petersburg</b><br>1967-1986    | <b>IPL</b>         | 1,672         | 32.6                         | 100%                                    | 0%                                      | 42,535                    | <b>1,672</b>                            | <b>100%</b>                      | 95%                                      | Units 1 - 7   |
| 5. <b>Clifty Creek</b><br>1955-6     | <b>IKECorp</b>     | 1,209         | 32.7                         | 22%                                     | <b>78%</b>                              | 32,753                    | <b>0</b>                                | <b>0</b>                         |  | Units 1 – 5 <b>2015 (five units)</b><br>Unit 6  |
| 6. <b>Cayuga</b><br>1970-1972        | <b>Duke Energy</b> | 1,096         | 33.7                         | 64%                                     | <b>36%</b>                              | 66,962                    | <b>0</b>                                | <b>0</b>                         |  | Unit 1 - <b>2015</b> Unit 2 - <b>2015</b>   |
| 7. <b>Merom</b><br>1982-1983         | <b>Hoosier</b>     | 1,000         | 32.4                         | 100%                                    | 0%                                      | 14,689                    | <b>1,000</b>                            | <b>100%</b>                      | 90%                                      | Units 1 – 2   |
| 8. <b>Tanners Creek</b><br>1951-1964 | <b>IMP.Co</b>      | 980           | 34.1                         | 92%                                     | <b>5%</b>                               | 53,175                    | <b>0</b>                                | <b>0</b>                         |  | Units 1 – 3<br>Unit 4 – <b>2015 (580MW)</b>   |
| 9. <b>Harding St</b><br>1973-2002    | <b>IPLCo</b>       | 924           | 34.2                         | 100%                                    | 0%                                      | 51,016                    | <b>0</b>                                | <b>0</b>                         |  | Units 1 - 8   |
| 10. <b>Wabash R.</b><br>1953-1995    | <b>Duke Energy</b> | 918           | 32.4                         | 100%                                    | 0%                                      | 64,606                    | <b>0</b>                                | <b>0</b>                         |  | Units 1 – 5<br>Unit 6 - <b>2015</b>   |
|                                      | <b>TOTAL</b>       | <b>15,310</b> |                              |   |   | <b>551,134</b>            | <b>4,855</b>                            | <b>32%</b>                       |  |   |



# Indiana's 10 Largest Power Plants & Emission Controls (IDEM January 2007)

| Plant Name            | Boiler Unit            | Output Capacity (MW) | On Line (Year)   | Fuel Type           | NOx Control                           | NOx Control Efficiency (%) | PM10 Control     | PM Control Efficiency (%) | SO2 Control          | SO2 Control Efficiency (%) |
|-----------------------|------------------------|----------------------|------------------|---------------------|---------------------------------------|----------------------------|------------------|---------------------------|----------------------|----------------------------|
| <b>Gibson</b>         | 1,2,3,4,5              | <b>3,131</b>         | 1975-82          | Coal                | LNB & SCR                             | 50 – 90                    | ESP              | 99.1 – 99.7               | FGD                  | 82 – 91%                   |
| <b>Rockport</b>       | 1,2                    | <b>2,600</b>         | 1984 & 1989      | Coal (WY)           | LNB & OFA                             | -                          | ESP              | 99.82                     | -                    | -                          |
| <b>R.M. Schaffer</b>  | 14,15<br>16A-B Gas     | <b>1,780</b>         | 1976 -79<br>1979 | Coal (WY)<br>N. Gas | SCR & OFA                             | -                          | ESP              | 95.8 – 97.7               | -                    | -                          |
| <b>Petersburg</b>     | 1,2,3,4                | <b>1,672</b>         | 1967-86          | Coal                | LNB SCR<br>OFA                        | -                          | ESP              | 98.0 – 99.5               | Wet FGD scrubbers    | -                          |
| <b>Clifty Creek</b>   | 1,2,3,4,5,6            | <b>1,209</b>         | 1955-56          | Coal (WY)           | OFA & SCR                             | 45                         | ESP              | 98.4 – 99.3               | FGD                  | -                          |
| <b>Cayuga</b>         | 1,2<br>Turbine         | <b>1,096</b>         | 1970-72          | Coal<br>N. Gas      | Mod Burner<br>Wet injection           | 52.99 – 54.99<br>90.99     | ESP              | 99.0                      | FGD (U/C)            | -                          |
| <b>Merom</b>          | 1,2                    | <b>1,000</b>         | 1980-82          | Coal                | LNB & SCR                             | -                          | -                | -                         | Wet FDG scrubbers    | -                          |
| <b>Tanners Creek</b>  | 1,2,3,4                | <b>980</b>           | 1951-64          | Coal                | LNB & OFA                             | -                          | ESP              | 99.15 – 99.75             | -                    | -                          |
| <b>Harding Street</b> | 5 boilers & 6 turbines | <b>924</b>           | 1942-02          | Coal & Oil          | LNB & SNCR                            | -                          | ESP on 3 boilers | 99.40 – 99.47             | FGD 2008 on 1 boiler | -                          |
| <b>Wabash River</b>   | 5 boilers & Turbine    | <b>918</b>           | 1953-01          | Coal & Syngas       | Mod. Burners<br>Steam/water injection | 37.99 – 49.99<br>76.99     | ESP              | 98.49                     | -                    | -                          |


Note: LNB – Low NOx Burners,  
ESP – Electrostatic Precipitators  
U/C – Under Construction

SCR – Selective Catalytic Reduction,  
OFA – Overfire Air

FGD – Flue Gas Desulfurization  
WY – Wyoming



# SO<sub>2</sub> Phase II Clean Air Act & Estimated CAIR Allowances on Indiana's 10 Largest Power Stations







## EPRI 2007 Analysis of Scrubber Technologies



- Multipollutant capabilities of new SO<sub>2</sub> control systems - will look at how well each system supports the co-capture & retention of Hg, reduction in opacity & PM<sub>2.5</sub> emissions, & possible moderate removal of NO<sub>x</sub>, while providing reliable, high levels of SO<sub>2</sub> removal
- Determine how FGD suppliers & architect/engineers are minimizing water consumption
- Provide a system that uses microchip-based sensors that could facilitate & expand FGD chemistry measurements