

21 2000 – Fire Suppression Piping

Page 1 of 1

Last Update: July 1, 2005

Mechanical Couplings:

Victaulic & Gruvlok style connections may be used on fire sprinkler systems inside of the buildings.

Table 1

Pipe Material Schedule		
Duty	Pipe Size	Type
Fire Protection	Before BFP	Sch 40 galvanized steel or Ductile
	After BFP	Sch 10 black steel
	Exterior	Sch 40 black steel
	Dry System	Sch 10 Galvanized Steel