

Form 14, Revised March 1997

Return To: PURDUE UNIVERSITY
PURCHASING SERVICES
401 S. Grant Street
West Lafayette IN 47907-2024

**** REQUEST FOR QUOTATION ****
This is NOT AN ORDER

RFQ NO.: X-1105 A1 Date: 08/20/09
Due Date: 08/27/09 By:2:00pm
Fax Response to (765) 494-6609 or Email to
vedward@purdue.edu

TO: ALL BIDDERS

To assist us in complying with Federal Guidelines, please verify the following classifications, noting changes where appropriate:

YES NO

Minority Business
Small Business
Woman-owned Business

SPECIAL INSTRUCTIONS

- Quotations received after due date may not be considered.
- Please advise of correct part number and/or description if incorrect or insufficient. This will expedite our processing the quote and order in the future.
- Please advise of correct address for order placement.
- We reserve the right to accept all or part, or to decline to buy the whole. THERE IS NO OBLIGATION TO BUY.
- We are exempt from Federal Excise Tax and Indiana Sales Tax (#003123723-004-1)

FREIGHT ROUTING INSTRUCTIONS

- Unless otherwise requested, quotations should be quoted FOB - SHIPPING POINT, FREIGHT COLLECT. Preferred carriers: Roadway & USF Holland Inc. If quoting FOB - DESTINATION terms, the unit of cost of goods quoted MUST BE ITEMIZED INDEPENDENTLY, WITH FREIGHT COST SHOWN AS A LINE ITEM, FOR QUOTATION TO BE CONSIDERED.
- Estimated shipping weight, and the city that the shipment will originate from are extremely important elements of this quotation and MUST BE INCLUDED TO BE CONSIDERED.
- If the product requires any special handling for transportation purposes, please note in the description of this document.

- If your company is awarded a Contract or Purchase Order under this RFQ, your company is subject to the following state requirements:
- Sales Tax Clearance. Indiana state law requires the University to submit certain information about Seller, including but not limited to, Federal Employee Identification Number (FEIN) to the Indiana Department of Revenue (IDOR) for sales tax clearance. If Seller is not registered in Indiana as a retail merchant or is delinquent in the payment or reporting of Indiana sales tax, the University is required to suspend further procurements from Seller until Seller resolves the problem with IDOR and IDOR issues a clearance to the University. Citations: House Enrolled Act (HEA) 1811 which, effective July 1, 2003, is promulgated in IC 5-17-1-11; IC 5-22-16-4; IC 6-2.5-14; IC 6-2.5-8-10.

****You are invited to submit a bid for a NATURAL GAS FIRED PACKAGE BOILER #7 FOR WADE UTILITY PLANT at Purdue University, West Lafayette, IN****

ADDENDUM NO. 1

The following changes shall be made to the specifications for the subject RFQ:

1. Page 48 51 55-12: Delete item 1.05 A.7, sub-items d and e. Heat transfer rates shall be in accordance with paragraph 1.03 B, C and D on page 48 51 55-2.
2. Page 48 51 55-15: Paragraph 2.01 F. Change ASTM SA 515 to **ASTM SA 515, ASTM SA 516 or approved equal.**
3. Page 48 51 55-15: Paragraph 2.01 G. Change ASTM SA 516 to **ASTM SA 515, ASTM SA 516 or approved equal.**
4. Page 48 51 55-24: Paragraph 2.05 B.3. Change 300 to **275.**
5. Page 48 51 55-24: Paragraph 2.05 C.1. Change four to **six.**
6. Page 48 51 55-25: Revise paragraph 2.06 B.2.a. to read as follows, "Emissions guarantees shall be from **10% to 100% MCR**".

Form 14, Revised March 1997

Return To: PURDUE UNIVERSITY
PURCHASING SERVICES
401 S. Grant Street
West Lafayette IN 47907-2024

RFQ NO.: X-1105 A1 Date: 08/20/09
Due Date: 08/27/09 By: 2:00pm
Fax Response to (765) 494-6609 or Email to
vedward@purdue.edu

7. Page 48 51 55-25: Add a new paragraph **2.06 B.2.c.** which reads as follows: **"VOC: The Boiler Manufacturer shall guarantee VOC emissions will not exceed 0.005 lb/MMBtu over the operating range from 10 to 100 percent MCR."**
8. Change paragraph headings from "2.06 B.2.d." and "2.06 B.2.e." to "2.06 B.2.e." and "2.06 B.2.f."
9. Page 48 59 61-1. Add the following Paragraph D to EQUIPMENT HANDLING:

"D. The Contractor shall temporarily remove the existing upper flanged portion of the decarbonator vessel which is located north of Column row A centered between Column Rows 15 and 16 to allow movement of the new boiler and appurtenances through this area. The existing vent pipe from the decarbonator shall be removed to the height necessary to move the new boiler into place and later reinstalled by the Contractor. The time that the decarbonator can be removed from service is limited to three days. Therefore, the upper section of the decarbonator which extends from an elevation that is just below the operating floor level must be removed just before the new boiler and appurtenances are to be moved into the building and must be placed back in operation as soon as possible after the new boiler and appurtenances are moved into the building. The removal of the upper section of the decarbonator will require coordination with Owner's plant operations to minimize the impact on operation of the plant. Temporary covers shall be placed over the lower section of the decarbonator which will remain in place as well as over the end of the upper section of the decarbonator that is to be removed by this Contractor."
10. Page 48 59 61-2. Add a new Paragraph **1.04 B**, which reads as follows

B. Installation of Instruments and controls: This Contractor shall install all instruments and controls furnished by the Boiler vendor, complete with all mounting brackets, isolations valves, three way manifolds, stainless steel tubing, and Swagelok fittings as required for a complete installation. Field electrical wiring will be provided by the Owner under a separate Contract.

PURDUE

UNIVERSITY

Page 3 of 3

Form 14, Revised March 1997

Return To: PURDUE UNIVERSITY
PURCHASING SERVICES
401 S. Grant Street
West Lafayette IN 47907-2024

**** REQUEST FOR QUOTATION ****
This is NOT AN ORDER

RFQ NO.: X-1105 A1 Date: 08/20/09
Due Date: 08/27/09 By: 2:00pm
Fax Response to (765) 494-6609 or Email to
vedward@purdue.edu

This signature page is to be signed, scanned and returned by e-mail immediately to Vicki Edwards at vedward@purdue.edu, and to Ed Barton at ebarton@ldbeng.com, and two copies of the addendum are to be printed, signed and submitted with the Proposal Documents.

SIGNATURE:

Name of Firm _____

Printed Name of Individual _____ Title _____

Address _____

FOR PURDUE UNIVERSITY:

ACKNOWLEDGED BY:

Vicki Edwards, C.P.M.

(765)494-7274

Signature _____

Office Hours
8 a.m. - 12 noon, 1 p.m. - 5 p.m.
E.S.T. Throughout Year

Signee Printed Name _____

Phone Number _____

Date _____

Prepared by: vae

Your Fax Number _____